




**ELETTROPOMPA AUTOADESCANTE
PER TRAVASO LIQUIDI
SELF-PRIMING ELECTRIC PUMP
FOR TRANSFERRING VARIOUS LIQUIDS**

**AVVERTENZE D'USO
INSTRUCTIONS FOR USE**

164 042 1C - UPX/AC 220 V



CE

DESCRIZIONE DEL DISPOSITIVO

A

Elettropompa autoadescante per travaso liquidi, particolarmente indicata per l'impiego nel settore alimentare, ove sia richiesto l'utilizzo di materiali inossidabili per tutte le parti a contatto con il liquido (vedere capitolo esclusioni), per uso discontinuo.

Gli elementi pompanti sono costituiti da ingranaggi in PTFE, che possono eventualmente girare a secco per brevi periodi. Completa di apposito filtro in linea sulla aspirazione.

DATI TECNICI

B

CODICE	TIPO	VOLT	FUSIBILE	PORTATA	PRESSIONE	PESO	P.ZI x CART.
CODE	TYPE	VOLT	FUSE	FLOW RATE	PRESSURE	WEIGHT	PCS x CART.
164 042 1C	UPX/AC	220	1,5 A	10 l/min	6 bar	4,6 kg	1

CONDIZIONI AMBIENTALI

C

TEMPERATURA : min. -10 °C / max. +60 °C **UMIDITA' RELATIVA** : max. 90 %

ATTENZIONE : le temperature limite indicate si applicano ai componenti del dispositivo e devono essere rispettate per evitare possibili danneggiamenti o malfunzionamenti. Lo stoccaggio deve avvenire in luogo asciutto rispettando le medesime temperature.

ALIMENTAZIONE ELETTRICA

D

L'elettropompa deve essere alimentata da tensione di rete alternata a 220V/50Hz. La pompa deve essere protetta da fusibile rispettando i dati tecnici.

CICLO DI LAVORO

E

La pompa è progettata per uso discontinuo. In condizioni di massima pressione (per esempio a mandata chiusa o ostruita, eccessiva lunghezza del circuito di mandata e/o cadute di pressione sugli accessori) la pompa subisce sollecitazioni superiori, pertanto si consiglia di non utilizzarla per tempi prolungati in queste condizioni.

APPLICAZIONI

F

I campi di applicazione della pompa sono molteplici, ma esclusivamente per i liquidi ammessi.

- trasferimento di fluidi alimentari
- trasferimento bevande
- travaso latte
- travaso paste fluide alimentari
- travaso oli alimentari

G FLUIDI AMMESSI / NON AMMESSI

AMMESSI :

ACQUA, FLUIDI ALIMENTARI: **max 40°C**

NON AMMESSI :

BENZINA

LIQUIDI INFIAMMABILI con PM < 55 ° C

LIQUIDI (densi) CON VISCOSITA' > 20 cSt

SOLVENTI

AGENTI CHIMICI INCOMPATIBILI CON
LE TENUTE

PERICOLI RELATIVI

INCENDIO - ESPLOSIONE

INCENDIO - ESPLOSIONE

SOVRACCARICO DEL MOTORE

INCENDIO - ESPLOSIONE

DANNI ALLE GUARNIZIONI

È responsabilità dell'utente accertarsi che i fluidi utilizzati siano compatibili con materiali utilizzati nella pompa (acciaio inox, PTFE, tenuta FKM, OR silicone).

H MOVIMENTAZIONE E TRASPORTO

Peso e dimensioni del dispositivo non richiedono per la movimentazione l'uso di mezzi di sollevamento particolari. In caso di movimentazione manuale utilizzare i normali dispositivi di prevenzione individuale (scarpe di sicurezza con puntale, etc...). Prima della spedizione la pompa viene accuratamente imballata. Controllare l'imballo al ricevimento ed immagazzinare in luogo asciutto.

I INSTALLAZIONE

Si raccomanda l'uso secondo le disposizioni vigenti in termini di sicurezza, e le precauzioni di seguito riportate.

I-1 SMALTIMENTO IMBALLO

Il materiale di imballo non richiede speciali precauzioni di smaltimento, non essendo in alcun modo inquinante o pericoloso. Per lo smaltimento fare riferimento ai regolamenti locali.

I-2 CONTROLLI PRELIMINARI

Controllare che la pompa non abbia subito danni durante il trasporto o lo stoccaggio. Pulire con cura le bocche di aspirazione e mandata rimuovendo eventuale polvere o materiale d'imballo residuo. Verificare che l'alimentazione elettrica disponibile corrisponda a quella richiesta dal dispositivo.

I-3 POSIZIONAMENTO DELLA POMPA

La pompa può essere installata in qualsiasi posizione. Fissare la pompa utilizzando viti adeguate ai fori di passaggio della flangia di appoggio.

ATTENZIONE : IL MOTORE DELLA POMPA NON E' DI TIPO ANTIDEFLAGRANTE. Non installare la pompa dove possono essere presenti vapori infiammabili o gas. Montare la pompa in zona ispezionabile. È buona norma evitare il contatto con spruzzi di acqua che possono provocare infiltrazioni nell'interno del motore con forte rischio di ossidazione e/o corto circuiti.

COLLEGAMENTO DELLE TUBAZIONI

I-4

- Prima del collegamento accertarsi che le bocche di aspirazione e mandata siano prive di tappi di spedizione;
- Non posizionare la pompa ad una altezza eccessiva rispetto al livello minimo possibile del fluido da trasportare. Se si supera l'altezza massima la pompa può non adescare rovinandosi.
- Evitare strozzature del tubo sia in aspirazione che in mandata in modo da ottimizzare le prestazioni.
- Si consiglia l'uso del filtro in aspirazione soprattutto con liquidi con consistente presenza di impurità (filtro a retino passo 0,5 mm). In questo caso eseguire una pulizia molto frequente del filtro. Il filtro di serie resiste ad una pressione massima positiva di 0,5 bar.
- Usare tubazioni e connessioni in materiale resistente ai fluidi trattati ed evitare dispersioni degli stessi nell'ambiente.

INSTALLAZIONE DELLA POMPA

I-5

La pompa va installata con collegamento elettrico dotato di protezione a fusibile dimensionato come indicato sull'etichetta del motore e in relazione al punto di utilizzo scelto.

IL MANCATO UTILIZZO DEL FUSIBILE FA DECADERE LA GARANZIA

Il dimensionamento dei cavi di alimentazione della pompa va effettuato in funzione della distanza della pompa dalla sorgente di alimentazione.

Fino a 40 metri di linea : 0,75 mm²

L'utilizzo di cavi sottodimensionati provoca il surriscaldamento degli stessi con reale pericolo di incendio. In tutti i casi si verifica caduta di tensione ai capi della pompa con relativa perdita di prestazioni.

La portata indicata sull'etichetta della pompa si ottiene utilizzando un tubo di diametro interno di 13 mm. Tubi di diametro inferiore provocano un maggior assorbimento di corrente e una perdita di portata.

ATTENZIONE: è responsabilità dell'installatore eseguire una installazione a norma e con corretto dimensionamento del circuito. È da considerarsi il grado di rischio dell'ambiente in cui viene installato il dispositivo.

L

PROBLEMI E SOLUZIONI

L-1 COSA VERIFICARE SE LA POMPA NON PARTE O SI ARRESTA?

- Verificare l'efficienza del generatore (presenza di tensione)
- Verificare se il fusibile è interrotto.
- Verificare la presenza di corpi estranei tra gli ingranaggi della pompa. Per effettuare tale verifica è necessario svitare le quattro viti di fissaggio, togliere il piattello di chiusura ed ispezionare l'interno della camera. A controllo eseguito il piattello va rimontato nella posizione iniziale.
- Evitare di far girare a secco per più di qualche minuto. **Le pompe riscontrate difettose per aver girato in assenza di liquido non sono coperte da garanzia.**

L-2

PERCHE' LA POMPA NON ADESCA ?

- La pompa è posizionata a più di 1,5 m di altezza dal livello del liquido.
- La pompa ha girato a secco per troppo tempo.
- Lunghi periodi di inattività. In questo caso è consigliabile introdurre direttamente del liquido nel corpo pompa prima dell'avviamento.
- Trafilamento di aria dal tubo di aspirazione a causa di:
Possibile presenza di tagli, mancanza di opportuna fascetta di serraggio, malfunzionamento del filtro dovuto alla guarnizione difettata/usurata, o filtro intasato.
Trafilamento di aria dal piattello a causa di :
Poca tenuta delle viti di fissaggio, guarnizione di tenuta poco efficace.
- Presenza di ostruzioni o restrizioni del tubo di aspirazione o di mandata.

L-3 AZIONI PER FAVORIRE IL BUON FUNZIONAMENTO DELLA POMPA

Se la pompa viene utilizzata per travaso di gasolio non necessita di particolare manutenzione. Se si prevede un periodo di inattività della pompa di almeno trenta giorni, soprattutto nel caso che si travasi acqua dolce o salata, si consiglia di far circolare acqua dolce ed allentare le viti del piattello del corpo. Al riutilizzo richiudere le viti dopo un breve avviamento della pompa (pochi secondi). Verificare che nelle condizioni di massima contropressione, l'assorbimento del motore rientri nei dati di targa.

MANUTENZIONE ORDINARIA

L-4

- Controllare frequentemente e mantenere pulito il filtro in aspirazione .
- Controllare mensilmente il corpo pompa e mantenerlo pulito da eventuali impurità.
- Controllare mensilmente che i cavi di alimentazione elettrica siano in buone condizioni.

INDICATORI DEL CORRETTO FUNZIONAMENTO DELLA POMPA

L-5

- Flusso regolare e rumore costante.
- Assorbimento di corrente compreso nei valori indicati nei dati tecnici.

APERTURA DELLA POMPA

L-6

Si consiglia di far intervenire del personale specializzato per effettuare riparazioni o sostituzioni di materiale d'usura all'interno della pompa, esclusivamente con ricambi originali.

Nel periodo di garanzia solo personale autorizzato di Marco S.p.A., pena decadenza della stessa

SMALTIMENTO

M


In caso di demolizione del dispositivo non disperdere nell'ambiente. Fare riferimento ai regolamenti locali.

GARANZIA

N

- 1) Il periodo di garanzia è di 2 anni dalla data d'acquisto come risulta dalla relativa fattura.
- 2) Nel caso la fattura non fosse disponibile il periodo di garanzia di 2 anni, sarà calcolato dalla data di fabbricazione.
- 3) La garanzia decade e s'intende nulla in caso d'utilizzazione non corretta o nel caso venissero ignorate le istruzioni contenute nel presente manuale.
- 4) La garanzia copre solamente i difetti di fabbricazione.
- 5) La garanzia non copre i costi connessi di installazione e smontaggio.
- 6) I costi di trasporto sono rimborsabili solo nel caso in cui la garanzia è stata debitamente riconosciuta e accettata da Marco S.p.A. Questi costi saranno limitati ai costi di spedizione tra il magazzino di Marco S.p.A. e la sede del cliente.
- 7) Nessuna nota di credito o reso sarà emessa prima di un test eseguito dal controllo di qualità di Marco S.p.A. che dichiari difettoso il prodotto.

SCHEDA DI ASSEMBLAGGIO



ART.	Q.TA'	DESCRIZIONE
1	4	VITE M4X10 TC A2 DIN 7985
2	1	PIATTELLO inox AISI 316 UPX
3	1	OR 2162 41,00X1,78 SILICONE
4	1	INGRANAGGIO trainante PTFE G423 UPX
5	1	INGRANAGGIO folle PTFE G423 UPX
6	1	PERNO Ø9X 24 AISI 316 UPX
7	1	CORPO UPX inox AISI 316
8	1	TENUTA MIM 9X22X7 SILICONE molla inox
9	1	CUSCINETTO 629 2RS
10	2	LINGUETTA AISI 316 A4 3x3x10 UNI 6604/A
11	1	ALBERO colleg. UP3/220 (Ø9 X 63 AISI 303)
12	4	VITE M5X25 TCEI A2 DIN 912
13	1	FLANGIA alluminio UP3/220
14	2	VITE M4X12 TCEI A2 DIN 912
15	1	GIUNTO ottone MEC 56 x UP3 220V
16	1	LINGUETTA FE 3x3x14 MEC 56
17	1	MOTORE monofase MEC 56 0,12KW 2poli B3/B14 220V 50hz
18	2	PORTAGOMMA 3/8 " M DELRIN UPX
19	4	OR 2056 14,00X1,78 SILICONE
20	1	RACCORDO nipplo 3/8 MM delrin UPX
21	1	FILTRO 3/8" FEMMINA
22	1	DISCO rete in acciaio AISI 304 x filtro
23	1	OR 2275 69,57X1,78 SILOPREN 70SH
24	1	FILTRO 3/8" MASCHIO

INGOMBRI





DIAGRAMMA PORTATE





DIAGRAMMA ASSORBIMENTI



ELENCO POMPE E ACCESSORI MARCO

ARTICOLO	DESCRIZIONE	TIPO	VOLT
1620011C	UP1 220V c.a. pompa girante in gomma 30 l	UP1	220
16200012	UP1 12V pompa girante in gomma 35 l		12
16200013	UP1 24V pompa girante in gomma 35 l		24
16200212	UP1-N 12V pompa girante in gomma 35 l	UP1-N	12
16200213	UP1-N 24V pompa girante in gomma 35 l		24
1640011C	UP3 220V c.a. pompa a ingranaggi 10 l	UP3	220
16400012	UP3 12V pompa a ingranaggi 14 l		12
16400013	UP4 24V pompa a ingranaggi 14 l		24
16400212	UP3/P 12V pompa a ingranaggi in PTFE 14 l	UP3/P	12
16400213	UP4/P 24V pompa a ingranaggi in PTFE 14 l		24
1640611C	UP6 220V c.a. pompa a ingranaggi 28 l	UP6	220
16406012	UP6 12V pompa a ingranaggi 26 l		12
16406013	UP6 24V pompa a ingranaggi 26 l		24
16402012	UP3/OIL 12V pompa per olio	UP3 OIL	12
16402013	UP4/OIL 24V pompa per olio		24
16408012	UP6/OIL 12V pompa per olio	UP6 OIL	12
16408013	UP6/OIL 24V pompa per olio		24
16410012	UP9 12V pompa per servizi gravosi	UP9	12
16410013	UP9 24V pompa per servizi gravosi		24
1640421C	UPX 220V c.a. pompa a ingr. 10 l inox	UPX	220
16404012	UPX 12V pompa a ingr. 14 l inox AISI 316		12
16404013	UPX 24V pompa a ingr. 14 l inox AISI 316		24
1640431C	UPX-C 220V c.a. pompa inox per chimici 10 l	UPX-C	220
16404112	UPX-C 12V pompa inox per chimici 14 l		12
16404113	UPX-C 24V pompa inox per chimici 14 l		24
16460012	UP3/A 12V autoclave	UP3/A	12
16460013	UP4/A 24V autoclave		24
16462012	UP6/A 12V autoclave	UP6/A	12
16462013	UP6/A 24V autoclave		24
16464012	UP9/A 12V autoclave per servizi gravosi	UP9/A	12
16464013	UP9/A 24V autoclave per servizi gravosi		24
16480012	DP3 12V pompa lavaggio ponte	DP3	12
16480013	DP3 24V pompa lavaggio ponte		24
16482012	DP9 12V pompa lavaggio ponte	DP9	12
16482013	DP9 24V pompa lavaggio ponte		24
16010012	UP500 12V pompa ad immersione	UP500	12
16012012	UP1000 12V pompa ad immersione	UP1000	12
16012013	UP1000 24V pompa ad immersione		24
16014012	UP1500 12V pompa ad immersione	UP1500	12
16014013	UP1500 24V pompa ad immersione		24
16016012	UP2000 12V pompa ad immersione	UP2000	12
16016013	UP2000 24V pompa ad immersione		24
ACCESSORI			
16510200	BQC connessione da incasso per rifornimento acqua dolce		
16510000	DQC connessione da incasso per pompa lavaggio		
16502000	OK1 kit tubi per pompe olio		
16508210	AT1 vaso espansione bianco 2 litri		
16508310	AT2 vaso espansione bianco 5 litri		
16508010	AT1X vaso espansione inox 0,5 litri		
16508110	AT2X vaso espansione inox 2 litri		

PRODUCT DESCRIPTION

A

Self-priming electric pump for the transfer of liquids, particularly suitable for use in the food industry, where it is essential that all parts in contact with the liquid are of non corrosive materials (see chapter of exclusions), for discontinuous use.

The pumping elements are made of PTFE gear drives which can possibly even run dry for brief periods. Completely equipped with in-line filter on the inlet side.

TECHNICAL DETAILS

B

CODICE	TIPO	VOLT	FUSIBILE	PORTATA	PRESSIONE	PESO	P.ZI x CART.
CODE	TYPE	VOLT	FUSE	FLOW RATE	PRESSURE	WEIGHT	PCS x CART.
164 042 1C	UPX/AC	220	1,5 A	10 l/min	6 bar	4,6 kg	1

AMBIENT CONDITIONS

C

Temperature: min. -10 °C / max. +60 °C **Relative humidity:** max. 90 %

Warning: the above indicated temperature ranges are applicable to all components of the pump and these limits must be respected in order to avoid any possible damage or malfunctioning.

ELECTRICAL CONNECTIONS

D

The electric pump must be connected to a 220VAC/50Hz power. The pump must be protected by a suitable rated fuse.

OPERATING CYCLE

E

The pump has been designed for discontinuous use. Under conditions of high operating pressures (eg. with closed or blocked outlet, excessive length of the delivery circuit and/or excessive pressure due to accessories), the pump can be subjected to elevated stresses and overheating and therefore should not be used for prolonged periods under such conditions.

APPLICATIONS

F

There are numerous fields of applications for the pump, however only exclusively with the allowed liquids mentioned:

- transfer of fluid alimentary paste
- transfer of beverages
- transfer of milk
- transfer of alimentary oils
- transfer of alimentary fluids

G FLUIDS ALLOWED / NOT ALLOWED

Allowed:

FRESH WATER, ALIMENTARY FLUIDS: **max 40°C**

Not allowed:

PETROL (GASOLINE)
FLAMMABLE LIQUIDS with PM < 55°C
LIQUIDS WITH VISCOSITY > 20 cSt
SOLVENTS
CHEMICAL PRODUCTS WHICH ARE
INCOMPATIBLE WITH SEALS.

Related dangers

FIRE - EXPLOSION
FIRE - EXPLOSION
MOTOR OVERHEATING
FIRE - EXPLOSION
DAMAGE TO SEALS

It is users responsibility to make certain that the fluids to be transferred are compatible with the materials used in the pump (stainless steel, PTFE, FKM seal, silicone OR).

TRANSPORTATION AND HANDLING

Due to limited weight and dimensions the pump does not require the use of any special handling or lifting equipment. When handling manually, normal personal protective gear should be worn (safety shoes with toe piece, etc.)

The pump is carefully packed prior to shipment. Upon receiving, the pump packaging should be inspected for damages and the pump stored in a dry area.

I INSTALLATION

It is recommended that the use of the pump be according to normative safety standards and also as per the precautions listed below.

I-1 PACKAGING ENVIRONMENTAL DISPOSAL

The packaging material is not in any way polluting or dangerous and does not require any special environmental disposal precautions. Disposal should be carried out according to local regulations in place.

I-2 PRELIMINARY CHECKS

Check that there has been no damage to the pump during transportation or storage. Both inlet and outlet ports should be carefully cleaned removing possible dust or residual packaging material. Verify that the available electrical power supply corresponds to the pump specification requirements.

I-3 POSITIONING OF THE PUMP

The pump can be mounted in any position. Fix the pump utilizing suitable diameter screws corresponding to the holes of the flange.

WARNING: THE PUMP MOTOR IS NOT EXPLOSION PROOF. Do not install the pump where flammable vapours or gases may be present. Install the pump in an accessible place for inspection.

It is good practice to avoid any pump contact with water splashes possibly causing water seepage into the motor with high risk of internal oxidation and/or short circuit.

TUBING CONNECTIONS

I-4

- Prior to making any tube/hose connections, check that the inlet ports have no end caps;
- Do not position the pump at a excessive height with respect to the minimum level of the fluid to be transferred. Damage may occur if this height is exceeded as the pump may not draw fluid. Make sure that the outlet tube is empty and without chokes
- Avoid choking the inlet or outlet tubes so that efficiency is optimized.
- The use of an inlet filter is recommended especially with fluids containing impurities (ASTM mesh 35). In this case frequent cleaning and maintenance of the filter is advisable. The standard filter withstands a maximum positive pressure of 0.5 bar.
- Utilize tubes and connection pieces that are resistant to the fluid types handled and avoid any possible environmental dispersion.

PUMP INSTALLATION

I-5

The electrical installation of the pump must include a protection fuse which is suitably rated as indicated on the motor label and sized with reference to the chosen point of application.

WARRANTY EXPIRES IF NO FUSE IS UTILIZED

Electrical cabling size should depend on the distance between pump and power source.

Over 40 m length: 0,75 mm²

The use of undersized cabling can cause overheating of the electrical wiring and subsequent fire hazard. There will also be a voltage drop at the motor terminals with a consequent reduction in efficiency.

The flow rate value indicated on the motor label is obtained with a 13 mm internal tube diameter. Tubes with inferior diameters will cause an increase in current with potential risk of motor overheating.

WARNING: it is the responsibility of the installation technician to ensure a correctly designed circuit installation fitted according to regulations. Environmental risks must be taken into account with the installation.

L

TROUBLESHOOTING

L-1 CHECK POINTS IF THE PUMP HAS STOPPED OR WILL NOT START

- Check the effectiveness of the battery power supply (voltage activity)
- Check if the fuse has blown
- Check for any foreign matter present in-between the pump gear drives. To do this, disconnect the power supply and unscrew the four fixing screws, remove the pump front cover plate and inspect the pump chamber. Replace the cover plate in the same initial position after inspection.
- Avoid running the pump dry for more than a few minutes. **Pumps found defective that have run dry in the absence of fluid are not covered by warranty.**

L-2

WHY THE PUMP WILL NOT PRIME ITSELF?

- The pump is fitted at a height greater than 1,5m above the fluid level.
- The pump has run dry for too long a period
- Long periods of inactivity. In this case it is advisable to add liquid directly into the pump chamber before start-up.
- Air leak at the suction pipe due to the following reasons:
 - Possible cuts in the pipe, inadequate hose clamps, malfunctioning of the filter due to defective/worn seals or filter clogged.
- Air leak at the pump front plate cover due to the following reasons:
 - Loose fixing screws, poor effectiveness of the seal.
- Presence of obstructions or restrictions in the suction or delivery pipes.

L-3

GOOD PRACTICES ENSURING A WELL FUNCTIONING PUMP

No particular maintenance is required if the pump is utilized for the transfer of diesel fluids. If it is expected that the pump will not be used for a period of at least 30 days, especially in the case of usage with fresh or salty water, it is advisable to run fresh water through the pump and to then loosen the pump front plate screws.

Upon re-use, run the pump briefly (a few seconds) and then tighten the screws again. Check under conditions of maximum operating pressure that the motor current value is within the motor label specifications.

NORMAL MAINTENANCE

L-4

- Check frequently and keep the inlet filter clean.
- Check every month the pump chamber and keep clean from any foreign matter.
- Check every month that electrical wiring is in good condition.

INDICATORS THAT THE PUMP IS FUNCTIONING CORRECTLY

L-5

- Regular flow and constant pump noise levels
- Amp-draw within the limits indicated in the technical details.

TO OPEN THE PUMP

L-6

It is recommended that a specialized service technician be consulted for any pump repair work or the replacement of worn out internal components, exclusively with original spare parts.

During the warranty period, only by authorized Marco S.p.A. personnel, failing which the warranty will expire.

ENVIRONMENTAL DISPOSAL

M

Should the pump be discarded, do not pollute the environment. Please refer to the local environmental regulations.


WARRANTY

N

- 1) The Warranty period is 2 years from date of purchase on production of the appropriate sales invoice.
- 2) Should the original sales invoice not be available, then the 2 year warranty period will be valid from date of production.
- 3) The Warranty becomes null and void in the case of incorrect utilization or disregard of the instructions contained herein.
- 4) The Warranty only covers original production defects.
- 5) The Warranty does not cover any related installation costs involved.
- 6) Transport costs are refundable only in the case where warranty has been duly recognized and accepted by Marco Spa. These costs will be limited to the actual shipment costs between Marco Spa warehouse and the client's delivery address.
- 7) No credit notes or replacement items will be issued prior to the receipt and proper testing of any Marco goods that are deemed faulty.

O



EXPLODED VIEW




ART.	Q.TY	DESCRIPTION
1	4	TOP PLATE SCREW M 4 X 10
2	1	TOP PLATE
3	1	TOP PLATE O-RING
4	1	DRIVING GEAR
5	1	IDLE GEAR
6	1	IDLE SHAFT
7	1	PUMP BODY
8	1	SILICONE LIP SEAL
9	1	BALL BEARING
10	2	KEY
11	1	SHAFT CONNECTION
12	4	SCREW M 5 X 25
13	1	COUPLING FLANGE
14	2	SCREW M 4 X 12
15	1	JOINT
16	1	MOTOR KEY
17	1	TWO-POLE MOTOR SINGLE PHASE 220 V 0,12 KW 50 HZ
18	2	TUBE OUTLET
19	4	O-RING
20	1	NIPPLE 3/8 "
21	1	FILTER HOUSING (FEMALE)
22	1	FILTER NET
23	1	FILTER O-RING
24	1	FILTER HOUSING (MALE)

P


DIMENSIONS



FLOW RATES DIAGRAM



AMPERE-DRAW DIAGRAM



MARCO PUMPS & ACCESSORIES LIST

ITEM	DESCRIPTION	TYPE	VOLT
1620011C	UP1 220V.a.c. rubber impeller pump 30 l	UP1	220
16200012	UP1 12V. rubber impeller pump 35 l		12
16200013	UP1 24V. rubber impeller pump 35 l		24
16200212	UP1-N 12V. rubber impeller pump 35l	UP1-N	12
16200213	UP1-N 24V. rubber impeller pump 35l		24
1640011C	UP3 220V.a.c. gear pump 10 l	UP3	220
16400012	UP3 12V. gear pump 14 l		12
16400013	UP4 24V. gear pump 14 l		24
16400212	UP3/P 12V. PTFE gear pump 14 l	UP3/P	12
16400213	UP4/P 24V. PTFE gear pump 14 l		24
1640611C	UP6 220V.a.c. gear pump 28 l	UP6	220
16406012	UP6 12V. gear pump 26 l		12
16406013	UP6 24V. gear pump 26 l		24
16402012	UP3/OIL 12V. gear pump for oil	UP3 OIL	12
16402013	UP4/OIL 24V. gear pump for oil		24
16408012	UP6/OIL 12V. gear pump for oil	UP6 OIL	12
16408013	UP6/OIL 24V. gear pump for oil		24
16410012	UP9 12V. heavy duty gear pump	UP9	12
16410013	UP9 24V. heavy duty gear pump		24
1640421C	UPX 220V.a.c. gear pump 10 l stainless-steel version	UPX	220
16404012	UPX 12V. gear pump 14 l stainless-steel AISI 316		12
16404013	UPX 24V. gear pump 14 l stainless-steel AISI 316		24
1640431C	UPX-C 220V.a.c. stainless-steel gear pump for chemicals 10 l	UPX-C	220
16404112	UPX-C 12V. stainless-steel gear pump for chemicals 14 l		12
16404113	UPX-C 24V. stainless-steel gear pump for chemicals 14 l		24
16460012	UP3/A 12V. automatic pump group with accumulator	UP3/A	12
16460013	UP4/A 24V. automatic pump group with accumulator		24
16462012	UP6/A 12V. automatic pump group with accumulator	UP6/A	12
16462013	UP6/A 24V. automatic pump group with accumulator		24
16464012	UP9/A 12V. heavy duty automatic pump group with accumulator	UP9/A	12
16464013	UP9/A 24V. heavy duty automatic pump group with accumulator		24
16480012	DP3 12V. washing services pump	DP3	12
16480013	DP3 24V. washing services pump		24
16482012	DP9 12V. washing services pump	DP9	12
16482013	DP9 24V. washing services pump		24
16010012	UP500 12V bilge pump	UP500	12
16012012	UP1000 12V bilge pump	UP1000	12
16012013	UP1000 24V bilge pump		24
16014012	UP1500 12V bilge pump	UP1500	12
16014013	UP1500 24V bilge pump		24
16016012	UP2000 12V bilge pump	UP2000	12
16016013	UP2000 24V bilge pump		24
ACCESSORIES			
16510200	BQC built-in boat quick connection for watering service from quay		
16510000	DQC built-in quick connection for washing pump		
16502000	OK1 tube kit for oil pump		
16508210	AT1 white painted metal accumulator tank 2 liters		
16508310	AT2 white painted metal accumulator tank 5 liters		
16508010	AT1X stainless steel accumulator tank 0,5 liters		
16508110	AT2X stainless steel accumulator tank 2 liters		



Associato AIB
associazione
industriale
bresciana

DICHIARAZIONE DI CONFORMITA' C.E. E.C. DECLARATION OF CONFORMITY

Confermiamo che il prodotto:
We confirm that the product:

164 042 1C - UPX/AC 220V Pompa ad ingranaggi 10 l / gear pump

E' conforme alle direttive 73/23/C.E.E. (relativa al basso voltaggio) e 89/336/C.E.E. (relativa alla compatibilità elettromagnetica) entrambe recentemente modificate con la direttiva 93/68/C.E.E. per l'uniformità legislativa degli stati membri della C.E.E.

Is in conformity with the E.C. directive 73/23/E.E.C. (Directive relating to low-voltage) and 89/336/E.E.C. (relating to the Electromagnetic Compatibility) both recently modified with the E.C. directive 93/68/E.E.C. for the laws uniformity of the E.E.C. states.

Questa dichiarazione è valida per tutti gli articoli prodotti secondo la documentazione tecnica che è parte di questa dichiarazione. In caso di eventuali verifiche pertinenti alla Sicurezza delle macchine elettriche e alla Compatibilità Elettromagnetica sono state applicate le seguenti normative:

This declaration is valid for all products which are produced in accordance with the technical documentation which is a part of this declaration. For verification of conformity with regard to the security of electric machines and to the Electromagnetic Compatibility the following standards are applied:

- | | | |
|---|---|---|
| ④ | EB60335-2-41:1990
+A51:1991 | Sicurezza delle macchine elettriche per uso domestico ed usi affini. Particolari applicazioni delle pompe elettriche con liquidi che non superano la temperatura di 35 °C.
<i>Security of electric machines for the domestic use and similar uses.
Particular applications of electric pumps with liquids that do not exceed 35°C.</i> |
| ④ | EN50081 - 1 / 03.93 | Normativa generica sull'emissione di disturbi radio (abitazioni, ambienti commerciali e piccole industrie).
<i>Generic emission standard, residential, commercial and light industry.</i> |
| ④ | EN50082 - 2 / 03.95
(ambienti industriali) | Normativa generica sulla resistenza ai disturbi radio
<i>Generic waves immunity standard, industrial environment.</i> |

Contrassegnazione con marchio CE da: Settembre '96
EC product marking from: September'96.

Questa dichiarazione è rilasciata sotto la responsabilità esclusiva di:
This declaration is given under the sole responsibility of:

MARCO S.P.A.
Via Mameli 10 - 25014 Castenedolo (Brescia)
Tel. 030/2134.1 Fax 030/2134.300

Per ulteriori informazioni vedere sito internet - www.marco.it
Marco S.p.A via Mameli,10 25014 Castenedolo - Brescia - Italy
tel. +39 030 2134.1 / Fax +39 030 2134.300

For further information visit the web site - www.marco.it
Marco S.p.A via Mameli,10 25014 Castenedolo - Brescia - Italy
tel. +39 030 2134.1 / Fax +39 030 2134.300